

Ventilated Area	Minutes per Change	Ventilated Area	Minutes per Change
Attic (entire home)	2-2 1/2	Laboratories	3-10
Assembly Halls	3-10	Laundries	1-3
Bakeries	1-3	Libraries	2-4
Bank	3-10	Locker Rooms	4-15
Barn	3-10	Markets	3-10
Bars	3-5	Mills	5-8
Beauty Parlors	3-5	Offices	5-12
Boiler Rooms	1-3	Packing Houses	3-5
Bowling Alley	3-10	Plating Rooms	1-5
Cafeterias	3-5	Pool Room	3-10
Chruches	2-4	Printing Shops	5-10
Clubs	5-7	Resturants	3-10
Dinning Room	3-10	Rest Rooms	5-10
Dormitories	5-8	Sales Rooms	2-10
Dry Cleaners	3-5	Schools	5-10
Engine Rooms	2-5	Shops	5-10
Factories	4-10	Stores	5-10
Foundries	2-8	Theatres	3-8
Garages	5-10	Toilets	2-5
Gymnasiums	3-10	Transformer Rooms	1-5
Kitchens	1-5	Warehouses	5-10